



Date : July 30, 1985

Reply to : Construction Engineer (WPCTC)

Attn of :

DATE OF LETTER

July 11, 1985

Subject: GS-11B-19067, Bid Package No. 3, Powerhouse Modifications, CIA
Headquarters Expansion, Langley, Virginia

To :

McI Constructors, Inc.
7649 Dynatech Court
P.O. Box 2786
Springfield, Virginia 22152

Gentlemen:

Your letter, dated above, submitting the following items for approval has been reviewed.

☒ Shop Drawings

☐ List of Materials

☐ Catalog Material

☐ Samples

☐

The listed items, subject to contract requirements and comments, are returned:

☒ Approved

☐ Not Approved

☐ Approved as noted

☐ For Resubmittal as noted

☐

MANUFACTURER AND DESCRIPTION	MFG. IDENTIFICATION	GSA NUMBER ASSIGNED
Vibro-Acoustics Silencer - Dwg No. 5655	McI Submittal No. 82	Approved

Sincerely,
Harry D. Lee
Construction Engineer

15616/30082

Submittal System – Contractor's Copy

Approved For Release 2005/11/17 : CIA-RDP02-06298R000900050001-9

Type
A - Add
R - Resubmit

Distribution

1. EDP

KP & KV

REVIEWED BY: CHERYL HERTZ, ICH

BF

0723 85

Discipline Routing						Responsibility					
63	65	66	68	69	71	72	74	75	77	78	80
<u>M</u>		<u>A</u>								<u>M</u>	
Routing Order											
<u>1</u>		<u>2</u>		<u>3</u>							
Checker/Trainer 6/27/15 6/27/15 6/27/15 6/27/15 6/27/15											

[illegible]

Approved For Release 2005/11/17 : CIA-RDP02-06298R000900050001-9

Submittal System – Add/Resubmit Form

Approved For Release 2005/11/17 : CIA-RDP02-06298R000900050001-9

Logged

MCI CONSTRUCTORS INC
Contractor's Name

7649 DYNATECH CT, SPRINGFIELD VA 22153
Address State

7-11-83
Mail Date

Type	Project No.	Contr. Suffix	Spec. Section	Page	Line	Actual Date In	Prom. Date Out	Manufacturer / Supplier
1	2	8 9	14 15	21	22 24 25 26	27 32	33 38	39
R	13155	C	15616	300	82			AIR TECH/B&W SALES

Type
A - Add
R - Resubmit

C.A. Name

E. MEDLING

Discipline Routing										Responsibility	
63	65	66	68	69	71	72	74	75	77	78	80

Routing Order

Distribution

1. EDP

KP & KV

REVIEWED BY: CHERYL HERBERICH

TSF

[illegible]

7.2.75

Approved For Release 2005/11/17 : CIA-RDP02-06298R000900050001-9

JUL 17 1985




MCI CONSTRUCTORS, INC.

7649 Dynatech Court
Springfield, Virginia 22153
Address replies to:
P O Box 2786
Springfield, Virginia 22152
Telephone (703) 569-8010
TWX 710-831-0333 MCI ALE



CLIENT: General Services Administration
PROJECT: CIA Headquarters Expansion
Bid Package 3 - Powerhouse Modifications
SUBMITTAL DATE: July 11, 1985
SUBMITTAL NUMBER: 82-R.1
SPEC. SECTION: 15616 VENDOR: B&W Sales
EQUIPMENT DESCRIPTION: FD & ID Fans
STATUS: Approved for submittal as clarified

C.Q.C. REPRESENTATIVE:


Brian J. Fleming

VARIATIONS AND CLARIFICATIONS

1. This resubmittal applies to the forced and induced draft fans as described in Specification Section 15616, Paragraph 20.
2. Note that revisions have been made to the following data; CFM, P.D. INS WG and insertion loss DB as corrected by GSA/SH&G.
3. Additional information has been noted concerning the finish and the end ring drillings quantity and spacing.



END RING
DRILLED QTY
12 - 1/2" DIA.
EQUI-SPACED
HOLES ON
26" P.C.D.

* FINISHED IN SHERWIN-WILLIAMS SERIES B 54 GREY ENA

TAG	QTY	I.D.	O.D.	L.	C.F.M.	P.D. INS WG	INSERTION LOSS DB.					CONST
							125	250	500	1K	2K	
24CCB-2T	3	24"	32"	48"	9.900 (MAX)	0.25	6	16	26	35	34	II

M.C.I.
CIA BID PKG. 13
SUBMITTAL 1
RESUBMITTAL 1
REC/APRVL

CASING		PERF.	MEDIA	EROSION PROTECTION	CONNECTIONS	NOTES
Class I Galv. Lockformed Steel []		Galv.	Compressed	Not Required [✓]	Slip []	INTAKE C/W W/FT BELL & SCREEN DISCHARGE END RING DRILLED WITH INTERNAL 1/2" NC WELDNUTS.
Galv. Spiral Steel []		Steel	Fiberglass	F.G. Cloth []	Flanges []	
Class II 16 ga. H.B.S. painted [✓]		22 ga		Mylar []	SEE NOTES	
ENGINEER		PROJECT		DRAWN BY	VIBRO-ACOUSTICS	
				BH.		
CUSTOMER		CIRCULAR SILENCER		CHECKED BY		
AIR TECHNOLOGY INC. ROSELLE, IL.		MODEL CCB		DATE	DWG. NO.	5655/R1